


Property Information			Contractor or Licensed Owner Information		
Building Name			Name		
Address		Address			
City		City	St.	Zip	
Contact Person		License #	Phone		
Phone		<input type="checkbox"/> SFM	Job #		
		<input type="checkbox"/> CSLB	Misc.		

This building has more than 5 risers. See additional AES 2.9 form attached Number of AES 2.9 forms attached

INSPECTION, TESTING, AND MAINTENANCE

I = Inspection T = Test M = Maintenance P = Pass F = Fail N/A = Not Applicable

Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
Inspection						
1.1	I	Backflow Preventer	Chapter 13			
1.2	I	Check Valves	Chapter 13			
1.3	I	Control Valves (sealed)	Chapter 13			
1.4	I	Control Valves (locked, supervised)	Chapter 13			
1.5	I	Deluge Valve	10.2.2, Chapter 13			
1.6	I	Detection Systems	NFPA 72			
1.7	I	Detector Check Valves	Chapter 13			
1.8	I	Drainage	10.2.8			
1.9	I	Electric Motor	10.2.9 Chapter 8			
1.10	I	Engine Drive	10.2.9 Chapter 8			
1.11	I	Fire Pump	10.2.9 Chapter 8			
1.12	I	Fittings	10.2.4, 10.2.4.1			
1.13	I	Fittings (rubber gasketed)	10.2.3.1, Annex			
1.14	I	Gravity Tanks	10.2.10, Chapter 9			
1.15	I	Hangers	10.2.4.2			
1.16	I	Heat (Deluge Valve House)	10.2.1.5 Chapter 13			
1.17	I	Nozzles	10.2.1.1, 10.2.1.2, 10.2.1.6, 10.2.5.1, 10.2.5.2			
1.18	I	Pipe	10.2.1.1, 10.2.1.2, 10.2.4, 10.2.4.1,			
1.19	I	Pressure Tank	10.2.10, Chapter 9			

Property Information		Contractor or Licensed Owner Information
Building Name		Name
Address		Job #
City		

INSPECTION, TESTING, AND MAINTENANCE

I = Inspection T = Test M = Maintenance P = Pass F = Fail N/A = Not Applicable

Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
2.13	T	Nozzles	10.2.1.3, 10.2.1.6, Section 10.3			
2.14	T	Pressure Tank	Section 10.2, Chapter 9			
2.15	T	Steam Driver	10.2.9, Chapter 8			
2.16	T	Strainers	10.2.1.3, 10.2.1.7, 10.2.7			
2.17	T	Suction Tanks	10.2.10, Chapter 9			
2.18	T	Water Flow Alarm	Chapter 5			
2.19	T	Valve Supervisory Signal Devices	Chapter 13			
2.20	T	Supervisory Signal Devices (Except Valve Supervisory Switches)	13.2.6.2			
2.21	T	Water Spray System Test	10.3, Chapter 13			
2.22	T	Water Supply Flow Test	7.3.1			
2.23	T	UHSWSS	10.4			
		Maintenance				
3.0	M	Backflow Preventer	Chapter 13			
3.1	M	Check Valves	Chapter 13			
3.2	M	Control Valves	10.2.1.4, Chapter 13			
3.3	M	Deluge Valve	10.2.2, Chapter 13			
3.4	M	Detection Systems	NFPA 72			
3.5	M	Detector Check Valve	Chapter 13			
3.6	M	Electric Motor	10.2.9, Chapter 8			
3.7	M	Engine Drive	10.2.9, Chapter 8			
3.8	M	Fire Pump	10.2.9, Chapter 8			
3.9	M	Gravity Tanks	10.2.10, Chapter 9			
3.10	M	Pressure Tanks	10.2.6, Chapter 9			
3.11	M	Steam Driver	10.2.9, Chapter 8			

